

**ADDENDUM NO. 1
TO
CONTRACT DOCUMENTS
FOR
2015 City of San Luis Obispo Water Resource Recovery Facility Influent Pump Replacement
Project, Specification No. 91419**

December 16, 2015

BIDS DUE Thursday, January 7, 2016, at 3 PM local time

The purpose of this addendum is to modify the contract documents. This addendum shall become part of the contracted documents. Acknowledge receipt of this addendum by completing the Bid Form and listing this addendum in Section F, page 14 of the IFB, and completing the acknowledgement section at the end of this addendum and attaching the executed acknowledgement to the proposal.

A. The following revisions are made to the Contract Documents:

CHANGES TO SPECIFICATIONS

1. Section 004100 – Replace Section 004100 Section 3.01.B, “Pump Data” with the following:

Pump Data

Capacity (gpm)	Pump Total Head (feet)	Minimum Pump Efficiency (%)
3472	13	73
2778	16	78
2083	20	70

THE BIDDER SHALL EXECUTE AND ATTACH THE FOLLOWING CERTIFICATION TO THE PROPOSAL.

BIDDER'S CERTIFICATION

I acknowledge receipt of the foregoing Addendum No. 1 to Contract Documents for 2015 City of San Luis Obispo Water Resource Recovery Facility Influent Pump Replacement Project, Specification No. 91419, and accept all conditions contained therein:

Dated: _____

Bidder: _____

By: _____