

**ADDENDUM NO. 2
TO
CONTRACT DOCUMENTS
FOR
2015 City of San Luis Obispo Water Resource Recovery Facility Influent Pump Replacement
Project, Specification No. 91419**

December 28, 2015

BIDS DUE Thursday, January 7, 2016, at 3 PM local time

The purpose of this addendum is to modify the contract documents. This addendum shall become part of the contracted documents. Acknowledge receipt of this addendum by completing the Bid Form and listing this addendum in Section F, page 14 of the IFB, and completing the acknowledgement section at the end of this addendum and attaching the executed acknowledgement to the proposal.

A. The following revisions are made to the Contract Documents:

CHANGES TO SPECIFICATIONS

1. Section 432120 – Section 2.12A, replace Impeller material and specification with the following:

Component	Material	Specification
Impeller	iron-nickel-chromium alloy	ASTM A532, Class 1, Type D

THE BIDDER SHALL EXECUTE AND ATTACH THE FOLLOWING CERTIFICATION TO THE PROPOSAL.

BIDDER'S CERTIFICATION

I acknowledge receipt of the foregoing Addendum No. 2 to Contract Documents for 2015 City of San Luis Obispo Water Resource Recovery Facility Influent Pump Replacement Project, Specification No. 91419, and accept all conditions contained therein:

Dated: _____

Bidder: _____

By: _____